

RECOMMENDED

MAINTENANCE FREQUENCY

Plug-in



6163 Boul Bourque,
Sherbrooke, QC J1N 1H2



1 800 864.7879





dauphinais.co



DAUPHINAIS


Condensing unit cleaning

Frequency : At least every three months



Drain cleaning

Frequency : At least every three months



Evaporation pan cleaning

Frequency : At least every six months

